



**MINISTRY OF PUBLIC UTILITIES
GOVERNMENT ELECTRICAL INSPECTORATE DIVISION**

Renewable Energy Generation Systems Inspection Requirements

1. All installations must comply with the Trinidad and Tobago Wiring Code – Part 3: Renewable Energy Systems and Interconnection Requirements (TTS 171: Part 3 (2011)) in addition to TTS 171: Part 1 and TTS 171: Part 2
2. The following information must be submitted with an application for inspection:
 - a) A line diagramme of the Distributed Renewable Energy System
 - b) The specification for all equipment that is to be installed
 - c) A copy of the manufacturer's installation instructions
 - d) A schedule of works for the installation
3. Safe access to all portions of the installation must be provided for all inspectors visiting the site.
4. For a wind turbine system, safe access to the site must be provided before the assembly and erection of the tower.

